



NP1:  
RECTIFIER AC INPUT  
CB201

NP2:  
RECTIFIER DC OUTPUT  
CB202

- NOTES:
1. DEVICE LEGEND (ALL DEVICES LOCATED BEHIND RIGHT FRONT DOOR)  
CB201 – RECTIFIER AC INPUT CIRCUIT BREAKER  
CB202 – RECTIFIER AC OUTPUT DISCONNECT SWITCH
  2. ALL DIMENSIONS EXPRESSED AS: INCH [MILLIMETER]
  3. RECOMMENDED MINIMUM CLEARANCES:  
FRONT 36.00 [914.40], REAR 0.00 [0.00], TOP 12.00 [304.80], SIDES 0.00 [0.00].
  4. SYSTEM MUST HAVE ALL PANELS AND DOORS INSTALLED FOR PROPER OPERATION.
  5. SQUARE BEVEL WASHER (16-2/3% SLOPE) NEEDED AT BOLT-DOWN HOLES WHEN EQUIPMENT IS TO BE BOLTED TO FLOOR.
  6. FINISH: LT. GRAY ENAMEL PER CYBEREX PAINT SPEC A-79699.
  7. OVER CURRENT PROTECTION MUST BE PROVIDED FOR ALL INPUTS TO THE SYSTEM (AC & DC). ALL APPLICABLE CODES MUST BE OBSERVED. CONSULT THE INSTALLATION SECTION OF THE MANUAL FOR SPECIFIC EQUIPMENT INSTALLATION INFORMATION.
  8. INSTANTANEOUS INRUSH ON NORMAL SOURCE ENERGIZATION MAY BE 4X RATED FOR 1/2 CYCLE.
  9. CABINET INTERCONNECTIONS ARE SUPPLIED BY CYBEREX. WIRES ARE DISCONNECTED FOR SHIPMENT, TAGGED AND COILED UP INSIDE OF CABINETS. WIRES MUST BE RECONNECTED AT TIME OF INSTALLATION.
  10. NAMEPLATES: PHENOLIC, ADHESIVE BACKED, BLACK LETTERS ON WHITE BACKGROUND, MACHINE ENGRAVED BEVELED EDGES.

MODEL	WEIGHT	
	LBS	KG
RBE-130-300-XXX-33-60	1450	658
RBE-130-400-XXX-33-60	2250	1020
RBE-130-500-XXX-33-60	2625	1190

CUSTOMER NAME  
P.O. #

**CYBEREX**  
RECTIFIER - RBE  
OUTLINE & MTG DIMS  
125V/300-500VAMP

ORDER -	SCALE	DRWN	QIB	CHGC	ME
ISSUE	ECNR	DESCRIPTION	BY	APPROV	DATE

ThomasBerets  
Power Solutions

DWG. SIZE NUMBER  
**D63039-2**

SHEET 1 OF 1